

3. Strategic framework in the field of energy efficiency

Energy Development Strategy and Energy Efficiency Action Plan

Preparation of the strategic framework in the field of energy efficiency is defined by EU directives which Montenegro has obligations to transpose as a member of the Energy Community.

The Law defines strategic setup as the Efficient Use of Energy. The Energy Development Strategy of Montenegro until 2030 represents the main strategic document for energy and energy efficiency. By EED, Montenegro should adopt three-year energy efficiency action plans. From 2010, Montenegro adopted four Energy Efficiency Action Plans (APEE). The last 4th APEE covering the period 2019-2021 was adopted by the Government of Montenegro in June 2019. This EEAP has a double significance, and it represents the following:

1. a comprehensive document for implementation of the energy efficiency policy on the side of final consumption of energy for the next three-year period;
2. a report with a detailed review of activities implemented in the previous period and an evaluation related to achieved energy savings compared to the targets set during the last EEAP.

Also, according to EED, EEAP sets indicative energy savings targets. 4th EEAP has continued the trend of the energy saving target from the previous period at the level of 1% annually (4.16 ktoe expressed in final energy). Unfortunately, data on the indicative energy saving target are not available for the last EEAP but for the period 2010-2018, 49.76 ktoe of energy savings is achieved, representing 84.5% of the overall indicative target for the nine years.

4th EEAP expired at the end of 2022, and Montenegro didn't adopt the new EEAP. The plan is that the adoption of future EEAPs is canceled and that energy efficiency policy is planned under the National Energy and Climate Plan (NECP), which should represent a comprehensive planning document in the energy field.

Also, according to the required form of the EED, in December 2019, the Government of Montenegro adopted the Plan for the Reconstruction of State-Owned Official Buildings for the Period 2020-2022 to fulfill the objectives of the mandatory reconstruction of administrative buildings. Target on public administrative building reconstruction at the level of 1% annually was set by the Government Decree on the reconstruction of administrative buildings (Official Gazette of Montenegro, 09/16), and the advantage is given to buildings

with the most unfavorable energy performance. Financing for public buildings reconstruction is provided within the "Energy Efficiency Program in Public Buildings - EEPPB," financed by KfW bank.

EEAPs, as crucial planning documents in the previous period, were a reasonable basis for implementing priority activities on improving energy efficiency in all sectors of energy consumption: buildings, households, services, industry, and transport.

Achieved results concerning implementing the planned measures are at a desirable level for actions related to establishing a legal framework, raising awareness, and executing promotional projects.

For the building sector, notable results were achieved only in the public sector through the implementation of dedicated projects financed from loans provided by the International Bank for Reconstruction and Development (IBRD) - **Montenegro Energy Efficiency Project (MEEP)** and German Development Bank (KfW) - **Energy Efficiency Program in Public Buildings (EEPPB)**, aimed at improving the energy performance of health and educational facilities. An overview of the financing and number of refurbished facilities is given in Table 3, and more detailed information on both projects is provided in Annex 1. Both projects started more than ten years ago and are still active. Phase 2 is ongoing for the MEEP project and is planned to be completed at the end of 2023. For the EEPPB project, Phase 3 started in 2021 under the title "Promotion of energy efficiency in public buildings - Greening Public Infrastructure in Montenegro" with allocated funds of € 50 million provided by KfW bank and the EU.

Table 3: Overview of the projects for the improvement of EE in public facilities

Montenegro Energy Efficiency Project (MEEP)	Energy Efficiency Program in Public Buildings (EEPPB)
IFI: International Bank for Reconstruction and Development (IBRD)	IFI: German Development Bank (KfW)
Funds: € 17.5 mil. (€ 11.5 mil. Phase 1, € 6 mil. Phase 2 - ongoing)	Funds: € 36.183 (€ 13.44 mil. Phase I, € 22.743 mil. Phase II)
No. of refurbished facilities: 33	No. of refurbished facilities: 33

Besides that, last several years, the Government of Montenegro has been implementing projects aimed at supporting the household sector in the implementation of energy efficiency measures through several projects: **Energy Wood, Energy Efficient Home, Solarni katuni,**

and Montesol. Financial support for interest subsidy for loans is provided from the budget of Montenegro and donations. From 2013-2021, around 1530 households were supported to implement energy efficiency measures such as installing heating systems on modern biomass, installing thermal insulation on walls, and replacing facade joinery. Also, the Government of Montenegro has supported two projects to promote solar technologies for water heating and electricity production, under which 432 households were supported. An overview of the financing and number of supported households is given in Table 3, and more detailed information on both projects is provided in Annex 2.

Table 4: Overview of the support for EE improvement in the households

Energy Wood (Phases I, II, and III)	Energy efficient home (Phases 1,2 and 3)	Solari katuni (Phases 1, 2, and 3)	Montesol
Interest-free loans for the heating systems on modern biomass	Interest-free loans for modern biomass heating systems and high-efficiency heating pumps and improvement of the building envelope (walls and windows)	Subsidies for procurement of PV solar systems for electricity production on summer pasture lands	Interest-free loans for the solar collectors for water heating
Period: 2013-2017	Period: 2018-2021	Period: 2011, 2012 and 2016	Period: 2011-2015
Funds: € 455,000	Funds: € 348.565	Funds: 209.300	Funds: USD 300,000
No. of users: 1,010	No. of users: 520	No. of users: 297	No. of users: 135

Although the implementation of specific promotional projects is ongoing, there is a need for a more sustainable way of financing energy efficiency projects. The 4th EEAP also recognizes this - establishment of a sustainable model for the funding of energy efficiency projects is planned through the Eco-Fund, which foundation is defined by the Law on Environment ("OG of MNE," no 52/16). The Eco-Fund functioning is based on the funds which are provided from the budget of Montenegro, from the funds of eco-fees, domestic and foreign donations and loans, and other forms of financing, which are regulated in the Law on Environmental Protection. Through the Eco-Fund, implementing the "polluter pays" principle will provide funds for the performance of projects to improve the environment. Necessary conditions for the operation of Eco-fond were created back in 2019/2020. In 2021/2022, Eco-fund has continued to build its capacity for implementing different projects and has started the project intending to support the introduction of clean viceless and installation of solar photovoltaics for citizens and businesses.

National Energy and Climate Plan (NECP)

One of the critical issues for Montenegro is the development of the **National Energy and Climate Plan (NECP)** following the provisions of *Regulation (EU) 2018/1999 on the Governance of the Energy Union and Climate Action*.

NECP is already recognized as a critical strategic document by the amendments of the Energy Law, which were adopted back on July 2020 (“Official Gazette of Montenegro” No. 82/2020), and that will determine the goals and mechanisms for increasing the share of RES, as a critical element of decarbonization and improvement of energy efficiency.

Activities on the development of the first NECP were started back in 2020. Support for the preparation of NECP was provided within program CDCP III (Capacity Development for Climate Policy in the Countries of South-Eastern, Eastern Europe, South Caucasus, and Central Asia, Phase III) implemented by GIZ in close cooperation with the Energy Community Secretariat to fulfill the prescribed obligations. So far, a draft of the NECP has been prepared, and the Energy Community Secretariat has received an initial set of comments. Finalization of the NECP is planned for the beginning of 2023, together with the Strategic Environmental Assessment, which will ensure that the environmental and health issues are fully considered while developing this crucial document in the energy field.

The finalization of the NECP is also affected by the decision to establish new 2030 targets at the level of the Energy Community, which is planned to be adopted in 2022.

4. Institutional framework

The **Ministry of Capital Investments (Ministry)** is responsible for developing and coordinating the implementation overall energy policy. According to the Law on Efficient Use of Energy, the Ministry is also responsible for the development of a legal framework following EU acquis, development of the EEAPs and monitoring of its implementation, coordination of international obligation and cooperation, implementation of the dedicated energy efficiency projects, organization of the promotional activities with the aim of awareness raising for energy efficiency, etc.

The main objectives and mission of the Ministry and its Directorate for Energy and Energy Efficiency were identified following the best EU practice and included:

- Identification, analysis, and proposition of technically possible and cost-effective policies and measures for EE improvement related to the energy consumption side
- Encouraging and promoting activities directed to savings and other EE activities, as well as reducing negative environmental impacts caused by energy conversions in energy consumption processes
- Promotion of RE use and use of other non-traditional sources with low environmental impact and
- Promotion and participation in sharing knowledge and information with similar authorities of other countries and with international institutions and associations active in the EE field

Therefore, the Ministry plays a crucial role in developing policy and legal framework for EE in Montenegro and monitoring its implementation.

It is worth mentioning that the importance of energy efficiency had lost its significance due to the organizational changes within the Ministry in 2019 when the Directorate for Energy Efficiency was merged with the Directorate for Energy and moved to the department level. This organization's intervention policy weakened support for energy efficiency, and its potential for further development by employing new servants was significantly reduced.

Other state institutions and local self-government units have certain obligations in planning and reporting on EE improvements in buildings and systems under their jurisdiction and introducing the energy management system. These obligations are prescribed by the Law on Efficient Use of Energy by the requirement form EED for the exemplary role of the public sector, meaning that public bodies' position regarding the reduction of carbon emissions,

better management of energy resources, and other environmentally impacting factors should be essential to encourage individuals, organizations and businesses to play their part.

Administration for Inspection Affairs play is responsible for inspection supervision of the implementation of provisions of this Law which includes the following:

1. Control of the placing on the market energy-related products
 - the energy-related product is not labeled with an energy efficiency label,
 - The energy-related product is not supported by the evidence of meeting the requirements concerning the eco-design of the product.
2. Control of fulfillment of obligations of the other entities:
 - actions of persons authorized to perform energy audits,
 - results of energy audit and energy certification of the building, if the accuracy of data is doubted,
 - implementation of the training program for performing energy audits and professional exams,
 - compliance with minimum energy efficiency requirements during construction of new buildings and reconstruction, adaptation respectively, of existing buildings,
 - timely and compatible planning and implementation of energy efficiency measures by obliged parties,
 - reporting of obligated parties on implementation of energy efficiency measures,
 - provision of data about energy consumption by obligated parties.

When financing energy efficiency projects more sustainably, it is essential to mention **Environmental Protection Fund (Eco Fund)**. The Eco Fund was established on March 2020 as a legal entity with the rights, obligations, and responsibilities determined by Law, the founding act, and the statute of the Company. According to the Law, the Eco Fund is financed by the budget of Montenegro, eco- fees, loans, donations, grants, European Union funds, United Nations and international organizations, foreign investments, and other sources prescribed by the Law. The activity of the Eco Fund is financing the preparation, implementation, and development of programmers, projects, and similar activities in the field of preservation, sustainable use, protection and improvement of the environment, energy efficiency, and use of renewable sources and energy at the state and local level.

The Eco Fund is expected to play a significant role in providing financial support for EE in Montenegro. It is important to emphasize that the Eco Fund may allocate funding in the forms of loans, subventions on commercial loan interests, and grants to the following categories of users:

- companies and other legal and natural persons registered following the Law
- local self-government
- state administration bodies and other independent legal entities financed from the state budget
- civil society organizations (non-governmental organizations, foundations, citizens' associations), and
- natural persons

Conduct Energy audits – experience from Montenegro

According to the Law on Efficient Use of Energy ("Official Gazette of the Republic of Montenegro" No. 57/2014 of December 26, 2014), energy audits of buildings and regular energy audits of heating and air conditioning systems can be performed by a company, an entrepreneur or a legal a person authorized to conduct energy audits - authorized person.

The authorization to carry out energy audits of buildings can be obtained by a company, entrepreneur, or legal entity that:

- Is registered in the Central Registry of Business Entities for the performance of, as a predominance, one of the following activities: design, construction, expert supervision of construction, revision of project documentation, and expert work in the field of energy;
- Has a person employed for an indefinite period with a completed university degree in the field of electrical engineering, mechanical engineering, construction, or architecture with at least five years of professional experience in the field of design, construction, professional supervision of construction, revision of project documentation, testing of energy plants or installations, and who has a certificate of passing the professional exam for performing energy audits of buildings - a qualified person for performing energy audits of buildings

The authorization to perform an energy inspection of the heating system and the air conditioning system can be obtained by a company, entrepreneur, or legal entity that:

- is registered in the Central Registry of Business Entities for the performance of, as a predominance, one of the following activities: design, construction, expert supervision

of construction, revision of project documentation, and expert work in the field of energy;

- has a person employed for an indefinite period with a university degree in mechanical engineering with at least five years of work experience in the field of design, management, and professional supervision of the installation of thermomechanical plants or facilities, testing of energy plants or facilities and who has a certificate of passing the professional exam for performing energy audits of heating systems and air conditioning systems - a qualified person for performing energy audits of heating systems and air conditioning systems.

A person authorized to carry out energy audits of buildings can carry out regular energy audits of heating systems and air conditioning systems if they employ a person as a mechanical engineer for an indefinite period who has a certificate of passing a professional exam for carrying out energy audits of buildings.

To obtain authorization to perform an energy inspection of the building, i.e., an energy inspection of the heating system and air conditioning system, a company, entrepreneur, or legal entity submits a request for authorization, with documentation proving the fulfillment of the conditions.

ANNEXES

ANNEX 1: INFORMATION ON PROJECTS FOR IMPROVEMENT OF ENERGY EFFICIENCY IN PUBLIC BUILDINGS

1. Montenegro Energy Efficiency Project (MEEP, MEEP AF)

The International Bank funded Montenegro Energy Efficiency Project (MEEP) for Reconstruction and Development (IBRD). In the project's first phase, the WB provided €11.5 million in two loans (an original loan of €6.5 million and an additional finance loan of €5 million). The €10.5 million was for the implementation of works, while € 1 was used for technical assistance.

The original loan (MEEP) became effective on 24 February 2009 and closed on 24 December 2014. The additional finance (MEEP AF) was realized from March 2014 to 31 March 2018.

The main project goal of MEEP and MEEP AF was to improve the energy efficiency of priority public sector facilities in Montenegro comprehensive by decreasing energy consumption, which will lead to lowering educational and health budget expenses on electricity (and other fuels), improving the level of comfort of the facilities premises, decreasing the operation and maintenance costs, reducing the greenhouse effect, and removing "light pollution" by focusing lighting.

The Ministry of Economy implemented the project in cooperation with the Ministry of Education and the Ministry of Health. Energy efficiency improvement was financed in 15 facilities in the education sector (schools and dormitories) and ten facilities in the additional finance in the health sector (hospitals and health centers). Typical measures implemented in these objects are facade and roof thermal insulation, replacement of external apertures, installation of thermostatic valves, boilers replacement, energy sources replacement, and lighting fixtures replacement.

The project's direct beneficiaries were 80,000 pupils, patients, and educational and health facilities employees, or 13% of the Montenegro population. Total savings for 25 facilities amounted to 8,011,989 kWh or 34% of baseline consumption (energy consumption in retrofitted buildings was reduced between 18% to 67% per facility) and a reduction of lifetime CO₂ emissions by 2,841 tons/year of CO₂ equivalents. Specific savings were from 24.3 kWh/(m²year) to 201 kWh/(m²year) per facility. The payback period of investments was from 6.4 - 27.7 years per facility. A summary of the results is given in Table 1.

Table 1: Energy savings and CO₂ emissions reduction after implementation of MEEP and MEEP AF

Savings type	Educational facilities	Heath facilities		Total
		Hospitals	Other facilities	
Annual energy savings	2,126,007 kWh/year	4,792,344.25 kWh/year	1,093,547 kWh/year	8,011,898 kWh/year
Energy savings	29% to 67%	17% to 64%	18% to 36%	18% to 67%
CO₂ emission decrease	664 t/year	1,750 t/year	426 t/year	2,841 t/year

2. Montenegro Energy Efficiency Project, phase 2- MEEP 2

The Montenegro Energy Efficiency Project, phase 2 (MEEP 2) development objective is to improve energy efficiency in health sector buildings and to develop and demonstrate a sustainable financing model.

The project aims to improve the energy performance of 20 health facilities, and work will be done to establish:

- Monitoring of the monitoring system, which will, in the first place, monitor the comfort levels in health facilities and
- A sustainable system of financing energy efficiency projects in the public sector. A sustainable financing system will enable, after the realization of the project's second phase, works on the application of energy efficiency measures in other health facilities to be financed from the savings realized in the adapted health facilities.

The project became effective on 1 September 2018, and the realization of the project will last until 31 December 2023. It will be financed by an International Bank for Reconstruction and Development (IBRD) loan of €6 million to Montenegro and contra-part funding (from captured energy cost savings and in-kind contribution of the Government of Montenegro).

EE improvements are planned at 20 facilities. So far, works on improving energy characteristics have been completed in 8 facilities: Health Centre Berane, Health Centre Plav and Health Centre Rožaje, General Hospital Bar, Health Centre Ulcinj, Special Hospital Risan, the Special Hospital Dobrota-Kotor, and the Health Center Tivat.

Typical measures implemented in these objects are facade thermal insulation, roof thermal insulation, replacement of facade joinery, installation of thermostatic valves, boiler replacement, and lighting fixtures replacement.

The results of measured energy savings available for the three facilities (health centers, Berane, Rozaje, and Plav) amounted to about 30% of the baseline consumption of these facilities, or between 68.3 kWh/ (m²year) and 92.1 kWh/ (m²year).

The preparation and implementation of the energy efficiency investments for buildings will be done using IBRD loan proceeds from 2021 until the MEEP 2 in the form of a joint co-financing arrangement between captured energy cost savings and IBRD loan proceeds.

3. Energy Efficiency Programme in Public Buildings (EEPPB - Phase I and II)

The project objective was to improve energy efficiency performance in targeted public sector buildings to develop a sustainable energy efficiency improvement program in the public sector. The program aims to improve the energy characteristics in selected facilities, optimize energy consumption and improve users' living and working conditions.

"Energy Efficiency Programme in Public Buildings (EEPPB)" is implemented in two phases based on loan and financial contribution agreements, signed with KfW Bank, for €13.44 million (Phase I) and €22.743 million (Phase II).

Phase I was realized from January 2012 to the end of 2015. The reconstruction and adaptation of 20 primary and secondary schools and one dormitory were carried out to improve users' energy efficiency and living and working conditions.

The Phase II of the "Energy Efficiency Programme in Public Buildings" was realized in January 2015 and is planned to completion in December 2020. Through this phase was planned reconstruction of 21 buildings, but due to lack of funds, 12 facilities were reconstructed. Includes the implementation of energy efficiency measures in:

- ten10 primary and secondary schools
- one1 social institution and
- one1 administrative facility.

Which are under the jurisdiction of the Ministry of Education, the Ministry of Labour and Social Welfare, and the Property Administration. For the remaining nine facilities, funds for reconstruction and adaptation will be provided from the next phase.

In addition to the above, Phase II includes activities on the establishment of energy management systems in facilities covered by the program, the establishment of an information system for monitoring energy and water consumption in the public sector, the development of a national inventory of buildings and procurement of software for energy performance. Energy audits and certification of facilities after the completion of energy efficiency measures.

Typical measures implemented in the objects:

A. Energy efficiency measures

- Installation of thermal insulation on facade walls.
- Replacement of facade joinery.
- Installation of thermal and waterproofing on the roof.
- Replacement of lamps with energy-efficient lamps.
- Introduction of a consumer management system.
- Replacement/improvement of heating systems, with the transition to biomass systems, where possible.

B. Structural measures:

- Constructive rehabilitation of buildings.
- Repair and repair the facade if it is not necessary to install thermal insulation.
- Construction of sidewalks around the building to preserve the facade.
- Removal of fixed elements on the facade (components for sun protection, etc.).
- Replacement of the roof structure.
- Replacement of damaged roof covering (tile, concrete slabs for flat roof, sheet metal, etc.).
- Installation of waterproofing on the roof in case thermal insulation installation is not necessary.
- Works on the stormwater drainage system.
- Reconstruction of electrical installations.
- Installation of a new lightning installation system.
- The access road to the boiler room.
- Reconstruction of other roofs (canopies, roofs above unheated space, etc.).

C. Measures to improve comfort:

- Painting works inside the building.

- Reconstruction of sanitary facilities, including the construction of sanitary facilities for the disabled.
- Replacement/repair of interior doors, glass surfaces, and shutters.
- Floor replacement/repair.
- Install nets on external windows, safety nets in gyms, etc.
- Spare parts.
- They were planting trees where the premises were exposed to the sun.
- Internal sun protection (curtains, blinds, etc.).
- Installation of ceiling fans.

The indicators of the reached objectives are achieved following energy consumption after measures: in the northern zone 150 kWh/m² a, in the central zone 125 kWh/m²a, and in the coastal area 100 kWh/m² a, with comfort requirements fulfilled.

According to the preliminary analysis results, the total savings for 33 facilities (21 from Phase I and 12 from Phase II) amount to 15,090,622 kWh, or 59% of baseline consumption (energy consumption in retrofitted buildings was reduced between 27.37% to 89.6% per facility).

Specific savings were from 18.4 kWh/(m²/year) to 349 kWh/(m²/year) per facility. Specific energy consumption after measures in educational buildings is between 21.7 kWh/m²a and 155 kWh/m²a, and for social care facility is 194 kWh/m²a. The average specific energy consumption is 97.7 kWh/m²a. The payback period of investments was from 6 to over 20 years per facility. The total reduction of CO₂ emissions for 33 facilities is 6,502 t/year.

4. Promotion of energy efficiency in public buildings - Greening Public Infrastructure in Montenegro

The project "Promotion of energy efficiency in public buildings - Greening Public Infrastructure in Montenegro" continues the hitherto successfully implemented "Energy efficiency programs in public buildings - phases I and II."

The project aims to improve EE in selected administrative buildings and educational and social institutions, as well as support fulfilling the obligations prescribed by the Law on Efficient Use of Energy, which arose from EU directives. This is intended to reduce greenhouse gas emissions and achieve the Intended Nationally Determined Contribution

(INDC). The overarching development policy aims to benefit the population and the environment from a sustainable, efficient, and reliable energy supply.

KfW will finance the project with a loan of up to €45 million. Also, a grant was provided by the European Commission through the Regional Energy Efficiency Fund (Reep Plus), through the Western Balkan Investment Framework (WBIF), for €4.785 million.

The project will include the following activities:

- construction of an administrative facility with an area of 5000-8000 m² for the needs of state bodies, which will be designed and built according to the highest European standards of energy efficiency,
- reconstruction and adaptation of administrative buildings under the jurisdiction of the Property Administration,
- reconstruction and adaptation of educational and social institutions to optimize energy consumption and improve the living and working conditions of users
- implementation of the Central Information System for monitoring energy and water consumption in the public sector and support to the public sector in establishing an energy management system, which is also a legally defined obligation,
- implementation of a series of accompanying measures that support the implementation of legal regulations, most of which resulted from the EU Directive on Energy Efficiency and the Directive on Energy Performance of Buildings and
- accompanying consulting services.

The planned period for the implementation of the program is 2020 - 2026. Preparatory activities are underway, and construction works are scheduled for the end of 2022/beginning of 2023.

ANNEX 2: INFORMATION ON SUPPORT FOR IMPROVEMENT OF ENERGY EFFICIENCY IN HOUSEHOLDS

1. Energy Wood (Phases I, II, and III)

The objectives of programs "Energy Wood – Phases I, II, and III" were: to provide households in Montenegro with interest-free loans for the purchase and installation of heating systems on modern forms of biomass (pellets, briquettes), reducing the risk of financial institutions entering a new market segment, encouraging the development of partnerships between commercial banks and distributors of biomass heating systems, as well as reducing total greenhouse gas emissions through the installation of biomass heating systems.

When it comes to end consumers, i.e., loan users, the program's goal is to offer households in Montenegro the opportunity to achieve economic and energy savings by using biomass heating systems, which would be purchased through interest-free loans.

This program's funds were used to implement and subsidize interest rates of commercial banks and participants in the program.

The program was implemented in three phases from October 2013 to December 2017. For the first phase, funds of €130,000 for the project implementation were provided from the "Fodemo" project, funded by the Government of the Grand Duchy of Luxembourg. For the second phase, funds were provided from a grant from the Government of the Kingdom of Norway for €240,000. For the third phase, funds for the program's implementation of €85,000 were provided from the budget of the Government of Montenegro.

€455,000 was provided for interest rate subsidies, and 1,010 heating systems were installed in Montenegrin households.

Estimated savings in CO₂ emissions are 966 tCO₂/year.

Under the "Energy Wood" program, citizens had the opportunity to apply for loans up to €3,500, with a repayment period of up to five years and an interest rate of 0%, for the installation of heating systems, i.e., furnaces and boilers, fuelled by modern forms of biomass.

2. Energy efficient home (Phases 1,2 and 3)

The "Energy efficient home" program is a continuation of the "Energy Wood" program, which has been expanded with other EE measures. The aim of the "Energy Efficient Home"

program is to offer the opportunity for households in Montenegro, through interest-free loans to achieve economic and energy savings by using biomass heating systems and high-efficiency heating pumps, "split" and "multi-split" systems and financing works to improve the energy performance of building envelope (installation of thermal insulation on facade walls residential building, installation of energy efficient joinery).

This program's funds were used to implement and subsidize interest rates of commercial banks and participants in the program.

Phases 1 and 2 were implemented from September 2018 to December 2019, while phase 3 was finished in December 2020. The total value of funds provided for the performance of all stages was €348.565 from the budget of the Government of Montenegro.

The total number of households where individual measures were implemented in all three program phases was 520.

Estimated energy savings under phases 1 and 2 of the program are 5,824 MWh/year, and CO₂ emissions savings are 367 tCO₂/year.

Under the "Energy efficient home" program, citizens could apply for loans up to €8,000 in Phase 1 and €10,000 in Phases 2 and 3 with a repayment period of up to 6 years and an interest rate of 0%.

3. Solarni katuni (Phases 1, 2, and 3)

The project "Solarni katuni" aimed to install solar systems for electricity production on facilities located on summer pasture lands, which are not connected to the electricity grid, to improve living and working conditions for households residing on summer pasture lands and to create conditions for increasing the number of farmers in summer pasture lands.

Phases 1 and 2 of the project were implemented in 2011 – 2012, while phase 3 was realized in 2016.

The total value of funds provided for implementing all phases was €264,370. €209,300 (80% in phases 1 and 2, 70% in phase 3) was provided in the form of a grant from the Ministry of Economy and Ministry of Agriculture and Rural Development. The remaining amount of €55,070 (20% in phases 1 and 2, 30% in phase 3) was paid by end users.

Within the project, 297 photovoltaic systems were installed on Montenegrin katuns.

The benefits of this project are that the installation of photovoltaic solar systems partially solves the electricity supply problem, which reduces the need for electrification of specific areas. The energy obtained in this way is free for users of facilities.

4. Montesol

The "Montesol" project aimed to establish an attractive and sustainable financial mechanism for providing loans to households for the installation of solar collectors. Other aims were economic and energy saving, loans for the installation of solar systems with a 0% interest rate, ensuring financial institutions' participation by reducing the risk of entering into a new market segment, creating a market for utilization of solar energy, contribution to an overall reduction of emission of harmful gasses.

The duration of the project was from February 2011 to April 2015. One hundred thirty-five households installed a solar system within this project.

The project was funded by a donation from the Italian Ministry of Environment, Land, and Sea (IMELS). For the needs of the "Montesol" project, funds in the amount of USD 848,670 were planned. Still, in 2015, the project was interrupted so that the total donation was USD 300,000, which was used to implement and subsidize the interest rate with commercial banks.

WP T1 – Pilot action
Project Main Output

Manual for Energy Efficiency
in Old and New Buildings
Country: Italy/Agnone Municipality



Premise

This document is drawn up in compliance with the provisions of the application form for the "REEHUB PLUS" project - Standards and training program of Energy Efficiency Audits and also has the purpose of detailing the results achieved in a path starting from REHUB up to arrive at REHUB PLUS highlighting the technical / synergistic aspects to which each of the partners has contributed.

State of the art

The main objective of this path was and is to provide knowledge and tools to the public administration, to young professionals (construction engineers, architects, mechanical engineers, electricians), to construction companies, to design studios, to organizations and individuals. (building administrators), for an adequate assessment of the results of energy audits in order to optimize efficiency measures on public and private buildings, also providing an indication of proper energy management of the buildings.

Knowledge indicates the result of the assimilation of information through learning and is the set of facts, principles, theories and practices, relating to a field of study or work described as theoretical and practical, therefore, the tools of which a professional will be able to use for the preparation of Energy Performance Certificate (EPC) starting from knowing in advance the building system / plants under study and this is how the results obtained with literature data can be analyzed compared to those actually present in the field.

In this context, the path taken with the construction of the HUBs (REEHUBs) and the energy audits developed in them has highlighted that the data available in the literature are not always necessarily interfaceable with real cases. It has therefore been seen how the adoption of "simplified" algorithms (ENEA development) has made it possible to highlight how the knowledge of the recovery / restructuring interventions carried out over time on a property can provide that extra input for a more precise reading of the data and therefore an optimization of the proposed interventions.

The study of the building / plant system passes, in addition to the knowledge of the "previous history", also for the acquisition of instrumental data, possibly with sampling in the long and medium term, which provide those inputs as in a time frame the building has dynamically modified its behavior under indoor / outdoor climatic conditions and use of the same. This need was reflected in the continuation of the project with "REEHUB PLUS" where

among the primary objectives there was precisely a measurement campaign carried out on the buildings indicated by the respective partners, which in the case of the Municipality of Agnone (MoA) were the headquarters of 'Municipal Administration and a recently built school. This choice was aimed at highlighting how technical interventions adopted on buildings of different historical / relational conception, which confirm their heterogeneity not only in architectural terms but also in use, may not always lead to the expected values.

The installation, in each of the buildings, of adequate equipment purchased with REEHUB PLUS, made it possible to study, by collecting remote data on a proprietary server, the behavior of the building system / plants in different climatic conditions.

In fact, the results obtained have highlighted how energy efficiency interventions performed after work "(for example with the only replacement of fixtures at the Agnone municipal administration office) do not return expected project values despite the goodness of the same intervention which does not will be able to guarantee an adequate behavior of the building / systems system The results obtained on the recently built school building were of a completely different nature, where, together with the fixtures, already in the construction phase, thermal insulation interventions were carried out by means of external coatings.

All the data of the measurement campaign, with monitoring of different quantities, are collected in a certified database in order to be able to provide a valid reference for future studies of a school building in conditions of daily use set in the context of a climatic zone "E ".

Therefore it appears extremely evident that not only the knowledge and the acquisition of information / data can constitute the basis for an adequate choice of interventions to be carried out, but the correct reading and interpretation of the same data constitutes the other fundamental element in the design of a high-performance building / plant system.

In light of the above, it is clear how trained technicians in this regard can represent the cornerstone of what has been explained. In this regard, training training activities were carried out, falling within the activities envisaged in the "Training organization (A.T.2.2- WPT2)" project for professionals in the sector.

The experience, therefore, gained in situ, the result of the study of the HUB as a laboratory of the building / plant system, has emphasized the need to promote an "energy" awareness already in school age, in particular in technical schools.

In fact, more and more convinced that the energy efficiency of a building starts from a common civic sense, it is also of fundamental importance to form a conscience in the technicians of tomorrow. Starting from this certainty, the elements that characterize REEHUB and REEHUB PLUS have been promoted at the first and true "workshop of minds", the school. Projects were carried out, with the help of the equipment purchased with REEHUB, involving the graduating students of the Technical Institutes. The students were shown how field study can immediately give the first design references, making the HUB of Palazzo Bonanni a real training ground for knowledge. To date, a portion of the young people involved attend energy universities or ITS. Therefore, the activities carried out with the active help of the HUB have already involved a large target group of technicians and students to whom to transmit knowledge and train that civic awareness on energy efficiency.

The implementation of the path briefly described above took into account all the regulations in force both in the European Community field, and in the national implementation as well as in compliance with the regulations of regional enactment.

HUB ENERGY AUDIT Palazzo Bonanni Agnone using the simplified algorithm (ENEA)

GENERAL DATA OF THE COMPLEX AND TERRITORIAL FRAMEWORK

Built in the thirteenth century, Palazzo Bonanni is an important noble building located in the oldest urban fabric of the city. Over the last few years the complex has been the subject of restoration interventions, aimed at enhancing the reuse of the building as a museum center and as a hub of the tourist, cultural and environmental network of the entire Molise area.

FUNCTIONAL AND DIMENSIONAL FEATURES

The building is structured in a single building with five floors, 4 of which are above ground and one basement. The premises intended to host the HUB are located on the second floor NORTH-WEST side.

SYSTEM CONFIGURATION OF THE COMPLEX

The complex has installed thermal systems for winter air conditioning and for the production of DHW, and electrical systems for lighting the rooms and for the operation of the electrical devices necessary for carrying out the activities. There are no summer air conditioning systems. Each of the floors is served by two methane-powered heat generators (boilers).

Each of the boilers is subservient to approximately half of the plan development of the single floor. At the time of the instrumental surveys on the floors below the one where the HUB was located, the heating systems were off with the exception of a wing on the ground floor.

PROJECT VALUES


The data used for the development of the energy AUDIT, of the HUB located inside Palazzo Bonanni located in the historic part of Agnone, are the result of a careful and analytical comparison between the data collected in the measurement campaign, from those hypothesized through the current literature and finally the feedback reported by the technicians who over time have carried out maintenance, conservation and renovation works on the building.

It should be noted that the comparison with the instrumental measurements, with particular relevance in the conductivity coefficient, carried out during the audit campaign envisaged in the project, allowed an evaluation of the transmittance making sure that the values obtained from the calculation are closer to the real one. structural situation compared to an evaluation carried out with theoretical values from the literature that would have underestimated a possible redevelopment intervention. As regards the measurements of consumption deducted from the billing made available by the MoA, both for electricity and methane consumption, it should be noted that at present the entire property is equipped with a single metering unit for electricity and two methane consumption metering groups (one of these is connected to the side of the ground floor intended to house the Municipal Police offices, while the other is dedicated to the rest of the structure).

Therefore, the available data refer to the total consumption of GAS for the entire building (6 boilers) and a POD relating to the entire use of the building (net of the premises intended for the Municipal Police).

1 - STRUCTURE ANALYSIS

Locali HUB	Reference plane	Side of the floor	Medium length (m)	Medium width (m)	Surface HUB (m ²)	Height (m)	Total area floor (m ²)
Rooms	SECOND FLOOR	Nord-Ovest	10	6,1	61	3,20	390




1.1 Stratigraphy of opaque vertical walls

The structure is characterized by vertical surfaces with the classic sack conformation, which is detailed below. Starting from inside the premises and moving from the inside to the outside of the wall, the building components are divided as follows:

1. Internal plaster: they are taken as references given by the current literature in particular for the thermal conductivity (EN1745) it is equal to $0,7 \text{ W/m}^{\circ}\text{C}$.
2. stone wall and air chamber, thickness 0.80 m (35 + 15 + 30)
3. External plaster: same characteristics used for the internal layer.

Table 2 shows the data used for the calculation of the quantities that will be expressed in subsequent paragraphs.



Layer	Thickness (m)	Coeff. Conductivity (W/m°C)	Density (kg/m ³)
Internal plaster	0,02	0,7	1500
Stone+C.A.+ Stone	0,80	2,2	2000
External plaster	0,02	0,7	1500

1.2 Slab stratigraphy (floor)

Proceeding, as above, from the basement upwards, we obtain the following layers:

1. Lime plaster: from the reliefs made the thickness is 2 cm and the thermal conductivity considered is **0,7 W/m°C**



2. Slab with brick blocks and joists: the thickness considered for this layer is equal to 30 centimeters while as regards the conductivity coefficient this has been taken equal to **0,7 W/m°C**

Layer	Thickness (m)	Coeff. Conductivity (W/m°C)	Density (kg/m ³)
Plaster	0,02	0,7	1500
Insole	0,3	0,8	1600
Flooring	0,05	1,2	2000

1.3 Slab stratigraphy (ceiling)

Also in this case we proceed upwards from inside the structure.

The subdivision of the layers will be as follows:

1. Wooden cladding
2. Plaster: same characteristics used up to now.
3. with brick blocks and joists: as in the previous case.

Layer	Thickness (m)	Coeff. Conductivity (W/m*°C)	Density (kg/m ³)
Riv. Wood	0,04	0,22	850
Plaster	0,02	0,7	1500
Insole	0,3	0,8	1600

1.4 Partition stratigraphy

The partition consists of a full-height vertical wall with the function of internally dividing the various rooms. It is structured like the one that attests to the outside, that is to bag

Layer	Thickness (m)	Coeff. Conductivity (W/m*°C)	Density (kg/m ³)
Internal plaster	0,02	0,7	1500
Stone + C.A. + Stone	0,80	2,2	2000

1.5 Doors and windows

The frames used include double-glazed windows (double glazing) characterized by a layer of simple glass with a thickness of 4 mm followed by a vacuum chamber, containing air with a thickness of 12 mm, and a final layer of simple glass of the same thickness as the first. .

The whole is enclosed by a wooden frame with the same conductivity of double glazing equal to $3 \text{ W/m}^2 \text{ } ^\circ\text{C}$.

2- CALCULATION OF THERMAL LOADS

In the following chapter, the working data will be set out and the thermal requirements required by the building / HUB rooms in the winter period will then be calculated.

2.1 Project data

The table shows the temperature and humidity data referring to the locality of Agnone in the winter period.

Project data	Winter
Temper. int. (°C)	21
Temper. exst. (°C)	-3

Humidity int. (%)	55
Humidity exst. (%)	65

2.2 Calculation of transmittance

With the data set out so far, we can proceed with the calculation of the transmittance for the various structural components of the building. It is still necessary to consider the effect on the transmission of heat through a surface due to the convective motions of the air masses both inside and outside the building.

Therefore, the following coefficients can be introduced:

- h_i = internal liminal heat transfer coefficient expressed in $W/m^2 \cdot ^\circ C$.
- h_e = external liminal heat transfer coefficient expressed in $W/m^2 \cdot ^\circ C$.
- S_i = single layer thickness expressed in m.
- K_i = conductivity coefficient expressed in $W/m \cdot ^\circ C$.

The coefficients assume, according to the UNI 7357 standard, the following values

	h_i ($W/m^2 \cdot ^\circ C$)	h_e ($W/m^2 \cdot ^\circ C$)
Vertical walls	8	25
Horizontal walls (ascending flow)	9,3	23,2
Horizontal walls (downward flow)	5,3	16,3

The thermal transmittance of a generic wall (U), expressed in $W/m^2 \cdot ^\circ C$, is equal to:

$$U = \frac{1}{\frac{1}{h_i} + \sum_{i=1}^n \frac{S_i}{k_i} + \frac{1}{h_e}}$$

where n refers to the number of layers present in the wall under examination.

For opaque vertical walls, the result is as follows:

$$U = \frac{1}{\frac{1}{h_i} + \sum_{i=1}^n \frac{S_i}{k_i} + \frac{1}{h_e}} = 1,89 \text{ W/m}^2 \cdot ^\circ C$$

For slabs (floor), the result is as follows:

$$U = \frac{1}{\frac{1}{h_i} + \sum_{i=1}^n \frac{S_i}{k_i} + \frac{1}{h_e}} = 1,44 \text{ W/m}^2 \cdot ^\circ C$$

For slabs (attic), the result is as follows:

$$U = \frac{1}{\frac{1}{h_i} + \sum_{i=1}^n \frac{s_i}{k_i} + \frac{1}{h_e}} = 2,07 \text{ W/m}^2 \cdot ^\circ\text{C}$$

$$U = \frac{1}{\frac{1}{h_i} + \sum_{i=1}^n \frac{s_i}{k_i} + \frac{1}{h_e}} = 1,89 \text{ W/m}^2 \cdot ^\circ\text{C}$$

Wall	U (W/m ² *°C)
Vertical	1,89
Flooring	1,44
Ceiling	2,07
Partitions	1,89
Doors and windows	3

3 - CALCULATION OF LOST THERMAL LOADS

Taking into account the project data set out in chapter 2, we proceed to calculate the dispersed thermal loads and useful ventilation.

3.1 Calculation of dispersed thermal power on opaque surfaces (Q_{do})

In this paragraph we proceed with the calculation of the powers dispersed by all the opaque surfaces.

The thermal power lost by an opaque surface can be expressed as:

$$Q_{do} = \sum_{i=1}^n \alpha_i \cdot U_i \cdot S_i \cdot \Delta t_i$$

Dove:

- α_i is the coefficient that takes into account the exposure of the wall
- U_i is the transmittance of the i-th wall W/m²*°C
- S_i is the internal surface of the i-th m²
- Δt_i is the temperature difference between inside and outside
- n represents the walls (North, South, West, East, ceiling and floor)

The value of α_i is a function of the exposure of the wall (UNI 7357, par.9); this coefficient, shown in the table below, is included for vertical surfaces between 1.02 and 1.20, and is equal to 1 for horizontal surfaces;

Esposizione	S	SO	O	NO	N	NE	E	SE
Coefficiente f	1	1,02-1,05	1,05-1,10	1,10-1,15	1,15-1,20	1,15-1,20	1,10-1,15	1,05-1,10

1Matte surface and breakdown $\diamond m^2 \diamond$

Matt Surface	Nord	Sud	Ovest	Est	TOT.
VERTICAL	19,36	17,6	29,6	33,12	99,68

Matt Surface	pavimento	solaio	TOT.
HORIZONTAL	54,57	54,57	109,14

$$Q_{do} = \sum_{i=1}^n \alpha_i \cdot U_i \cdot S_i \cdot \Delta t_i$$

NORD

Matt Surface	α_i	S	U	Δt	Q_{do}	$Q_{do} + 10 \text{ PERCENTO}$	$Q_{do} + 10 \text{ PERCENTO kW}$
Partitions	1,15	19,36	1,89	4	168,32	185,14	0,18

SUD

Matt Surface	α_i	S	U	Δt	Q_{do}	$Q_{do} + 10 \text{ PERCENTO}$	$Q_{do} + 10 \text{ PERCENTO kW}$
Partitions	1,02	17,6	1,89	4	135,71	149,28	0,15

EST

Matt Surface	α_i	S	U	Δt	Q_{do}	$Q_{do} + 10 \text{ PERCENTO}$	$Q_{do} + 10 \text{ PERCENTO kW}$
Partitions	1,15	33,12	1,89	4	287,94	316,73	0,3

OVEST

Matt Surface	α_i	S	U	Δt	Q_{do}	$Q_{do} + 10 \text{ PERCENTO}$	$Q_{do} + 10 \text{ PERCENTO kW}$
PARETE VERSO EST	1,05	29,6	1,89	24	1409,78	1550,68	1,55

Matt Surface	α_i	S	U	Δt	Q_{do}	$Q_{do} + 10 \text{ PERCENTO}$	$Q_{do} + 10 \text{ PERCENTO kW}$
HORIZONTAL FLLOR	1	54,57	2,07	21	2372,15	2609,15	2,6
FLOORING	1	54,57	1,44	21	1650,19	1815,19	1,82

Matt Surface	Q_{do}	$Q_{do} + 10 \text{ PERCENTO}$	$Q_{do} + 10 \text{ PERCENTO kW}$
Total	6024,09	6626,17	6,6

3.2 Calculation of dispersed thermal power on glass surfaces (Q_{dv})

$$Q_{dv} = S \cdot U \cdot \Delta t$$

The data used refer to the tables in the previous paragraphs. Also in this case the calculation was subject to a separation based on the orientation of the surfaces with respect to the cardinal points.

1. Glazed area and distribution [m²]

Glass surface	Nord	Sud	Ovest	Est	TOT.
Windows	/	/	6,21	/	6,21

Glass surface	S	U	Δt	Q_{dv}	$Q_{dv} + 10$ PERCENTO	$Q_{dv} + 10$ PERCENTO kW
Rooms	6,21	3	24	447,12	491,82	0,49

3.3 Calculation of total thermal power dispersed by opaque and glazed surfaces

Surface	total kW
Matt surface	6,6
Glass surface	0,49
TOTAL	7,09

$$Q_{dov} = Q_{do} + Q_{dv} = 7,09 \text{ kW.}$$

3.4 Calculation of dispersed power for ventilation (Q_{vent})

A certain amount of external renewal air enters all rooms due to infiltration through cracks or occasional opening of doors and windows.

The thermal power required to bring the aforementioned external air to the temperature of the heated environment (Q_{vent} thermal power dispersed by ventilation, also called ventilation thermal load) is equal to:

$$\dot{Q}_{vent} = \dot{V}_a \cdot c_{pv} \cdot (t_i - t_e) = V \cdot n \cdot c_{pv} \cdot (t_i - t_e) = V \cdot n \cdot c_p \cdot (t_i - t_e)$$

where is it

- \dot{Q}_{vent} = thermal power dispersed by ventilation, W (kcal/h);
- V_a = flow of incoming external air, m³/s (m³/h);
- V = net volume of the heated zone, m³;
- n = number of volumes of fresh external air, s⁻¹ (h⁻¹);
- c_p = mass heat capacity (specific heat) at constant air pressure, post equal to 1.000 J/kgK (0,24 kcal/kg°C);
- ρ = air density, set equal to 1,2 kg/m³;
- c_{pv} = volumic unit heat capacity (specific heat referred to the unit of volume) at constant air pressure, set equal to 1.200 J/m³K \cong 0,29 kcal/m³°C.

Moving on to the calculation

$$\dot{Q}_{vent} = \dot{V}_a \cdot c_{pv} \cdot (t_i - t_e) = V \cdot n \cdot c_{pv} \cdot (t_i - t_e) = V \cdot n \cdot c_p \cdot \rho \cdot (t_i - t_e)$$

design characteristics and conditions:

- site: **Agnone (IS)**
- ($t_e = -3$ °C)
- ($t_i = 21$ °C)

The room volume: 174,62 m³

- External replacement air: $n = 0,5$ h⁻¹ (usual average value)

From the assigned data it appears that the external air flow entering the room is:

$$V = n \cdot \text{Volume} = 0,5 \times 174,62 = 87,312 \text{ m}^3/\text{h} = 87,312/3600 \text{ m}^3/\text{s} = 0.024 \text{ m}^3/\text{s}$$

Therefore, the thermal power lost by ventilation is equal to:

$$Q_{vent} = 174,62 \times (0.5/3.600) \times 1000 \times 1.2 \times (21 - (-3)) \cdot = 698,48 \text{ W} \cong 0,7\text{kW}$$

Ventilation dispersions Q_{vent}		
Room	Volume m ³	Q vent (kW)
HUB	174,62	0,7

$$Q_{vent} = 0,7 \text{ kW.}$$

3.5 Calculation of latent thermal power (Q_{lat})

For the calculation of the Q_{lat}, an endogenous contribution due to the presence of people in the premises is assumed equal to 60W / persona, thus obtaining for the latent thermal power for the HUB with an average number of people present equal to 4

$$Q_{lat} \diamond 60W/persona \cdot 4 persone \diamond 240 W \diamond 0,24 kW$$

$$Q_{lat} = 0,24 kW.$$

3.6 Thermal load

In light of the above, it is possible to conclude that the thermal load that the system will have to restore in the face of the dispersions is given by the algebraic sum of the thermal power dispersed through the surfaces ($Q_{dv} + Q_{do} = Q_{dov}$), the power dispersed by ventilation and the endogenous contributions.

Thermal power dispersed opaque and transparent components	Q _{dov} (kW)	7,09
Thermal power dispersed by ventilation	Q _{vent} (kW)	0,7
Latent thermal power	Q _{lat} (kW)	- 0,24
Total dispersed thermal power	Q_{dov}+Q_{vent}-Q_{lat}	7,55 kW

Performance analysis of the installed heating unit

As regards the measurements of consumption deducted from the billing made available by the MoA, both for electricity and methane consumption, it should be noted that at present the entire property is equipped with a single metering unit for electricity and two methane consumption metering groups (one of these is connected to the side of the ground floor intended to house the Municipal Police offices, while the other is dedicated to the rest of the structure).

Therefore, the available data, provided by the MoA, refer to the total consumption of GAS for the entire property and a POD relating to the entire use of the property (net of the premises intended for the Municipal Police). Therefore, in order to analyze the performance of the HUB, we will refer to the data determined for the structure and the existing heat production plants.

Technological systems

List of technological systems installed in the complex, with the relative typological characteristics and the power produced or absorbed.

Condensing boiler for space heating and production of ACS Site HUB	Pot. foc. [kW]	Rend. utile nom.	Comb.	Terminal type	Served area (m ²)
	30	0.93	Metano	Radiatori	195

To check if the boiler installed meets the calculation parameters, we proceed with the analysis of the existing system with respect to the thermal load to be reintegrated and the efficiency of the system itself:

- To supply 7.55kW to the HUB premises, an emission system (radiators) is in place with an efficiency: 95%.
- Hot water passes through pipes that disperse a certain amount of heat and for these it can be assumed efficiency: 96%.
- The water is accumulated in a tank that disperses and for this reason it can be assumed that the efficiency is 98%.
- The regulation system does not control the peaks perfectly, yielding at times too much and at others too little and for this reason it can be assumed efficiency: 97%.
- Finally, the boiler is of the condensing type with thermal efficiency: 93%.

Therefore the minimum heat output of the boiler must be: $7.55 / (0.95 * 0.96 * 0.98 * 0.97 * 0.93) = 9.36$ kW which compared to the square meters of the HUB $9.36 / 61 \sim 0.15$ kW / m² In the case in question, the installed boiler has a thermal power of 30kW which must satisfy the part of the floor where the 195m² HUB is located therefore the thermal power $30/195 = 0.15$ kW / m² In light of the above, the nominal heat output of the boiler is suitably sized with respect to the needs of the

HUB.

Therefore the minimum heat output of the boiler must be:

$7,55 / (0,95 * 0,96 * 0,98 * 0,97 * 0,93) = 9,36$ kW which compared to the square meters of the HUB $9,36 / 61 \approx 0,15$ kW/m²

In the case in question, the installed boiler has a thermal power of 30kW which must satisfy the part of the floor where the 195m² HUB is located

therefore the thermal power $30 / 195 = 0,15$ kW/m²

In light of the above, the nominal heat output of the boiler is suitably sized with respect to the needs of the HUB.

Determination of the Primary Energy Required

In order to determine the Primary Energy Required, reference will be made to:

$$E_{pr} [\text{kWh/mq} * \text{anno}] = (Q_d + Q_v) * G_{Gr} * h_g / (S_u * DT^\circ * \eta_g)$$

With reference to the HUB in question, this is located in Agnone (IS) falling within the "E" climate zone. As regards $G_{Gr} = 2.457$.

- $S_u = 61$ mq;
- $P_n = 28$ kW;
- $G_{Gr} = 2.457$
- $Q_d + Q_v = 7,55$ kW
- $h_g = (576)$
- $DT^\circ = 24$ °C

$$\eta_g = \eta_p * \eta_d * \eta_e * \eta_r = 0,8066 \text{ in linea con i valori limiti}$$

$$\eta_g = (75 + 3 \log P_n) / 100 = (75 + 3 \log 28) / 100 = 0,7934$$

$$E_{pr} = (7,55 * 2457 * 384) / (61 * 24 * 80,66) = 60,32 \text{ kWh/mq} * \text{anno}$$

Performance analysis of the building / plant system

Referring to the available data, provided by the MoA, which refer to the total consumption of GAS for the entire property and a POD relating to the entire use of the property (net of the premises intended for the Municipal Police). Let's start from these by proportioning them to the surface of the HUB.

The plants belonging to the GAS supply measurement group are 6 in number, meaning that each of the three floors on which the property is developed is served by two boilers, all of the same type and power. Each of the portions of the floor served by the single boiler is equal to 195mq.

From what has been reported, the plants of the six present, which were actually used, served an area of 390mq, while the POD of the electricity carrier served 195mq.

Electric energy

Electricity consumption

Electric Energy	Consumption (kWh_e) year (three-year average 2017/2018/2019)
	5680,84 kWh/anno

Methane gas

Methane gas consumption

Methane gas	Consumption (m^3) year (three-year average 2017/2018/2019)
	2358,77 m^3 /anno

Let's start by transforming the m^3 of methane consumed on average in a year into kWh:

$$2358,77 \text{ m}^3 * 9,5 = 22408,315 \text{ kWh} \rightarrow 22408,315 / 390 = 57,46 \text{ kWh/mq} * \text{ yearC'comb.} \\ = 57,46 \text{ kWh/mq} * \text{ year}$$

$$DC_{\text{comb}} = C_{\text{comb}} - C'_{\text{comb}} = 60,32 - 57,46 \rightarrow 2,86 \text{ kWh/mq} * \text{ year}$$

$$DC_{\text{comb}} / C_{\text{comb}} = 2,86 / 60,32 = 0,0474 \quad 4,74\%$$

There is high congruity between the adopted model and the real one.

Calculation of the global consumption of primary energy

Let's start by transforming the m³ of methane consumed on average in a year into kWh:

$$2358,77 \text{ m}^3 * 9,5 = 22408,315 \text{ kWh} \rightarrow 22408,315 / 390 = 57,46 \text{ kWh/mq} * \text{ anno}$$


Similarly, we transform electricity into primary energy

$$5680,84 \text{ Kwh} * 2,174 = 12350,15 \text{ kWh} \rightarrow 12350,15 / 195 = 63,33 \text{ kWh/mq} * \text{ anno}$$

$$E_{prgl} = 57,46 + 63,33 = 120,79 \text{ kWh/mq} * \text{ anno}$$

4. INTERVENTIONS

In order to analyze any improvement interventions and evaluate the return times of any costs to be incurred, it is necessary to highlight that the structure of Palazzo Bonanni where the HUB is located is of historical and cultural interest, therefore this aspect excludes a whole series of redevelopment interventions, both in correspondence with the external walls and on the internal perimeter walls, the same applies to the horizontal ones (in correspondence with the wooden cladding roof slab, see photo).



THE MEASUREMENT CAMPAIGN

Wp T1 - Energy Performance Diagnoses of Public Buildings

As part of the activities envisaged in the project, a measurement campaign was carried out on the two buildings under study. definition of good practices to be adopted in the field of energy efficiency in order to create a tool that can be easily transferred to other public entities both on a regional and national scale in a cross-border cooperation perspective;

As part of the cooperation between the various partners in the context of measurements and surveys, the technical methodological aspects to be implemented for the specificity of the places, have been studied and implemented in synergy with ENEA technicians.

The data collected in the measurement campaign were promptly transmitted to the National Energy Technology District (DiTNE) through a final report which, in addition to the data collected by the other project partners, constitute a valid tool aimed at identifying the best solutions to be adopted. for local public bodies in order to optimize the energy performance of public buildings.

METHODOLOGICAL ANALYSIS

In accordance with the provisions of the project, the monitoring activities of the performance parameters necessary for the energy study of the buildings identified as part of WP T1 - Pilot action Identification of public buildings for energy performance diagnosis were carried out:

- The "School Complex "G.N. D'Agnillo", Piazza del Popolo, 31/A - 86081 Agnone (IS);
- Town Hall Municipal Administration, Salita G. Verdi, 9 - 86081 Agnone (IS);

The technical / design choice fell on the WiFi type instrumentation and dedicated software purchased with the project.

Specifically, devices were purchased that guarantee, in addition to the technical characteristics of the case, also a bidirectional management solution of the same, by interfacing with a single control unit and remote control of the data detected to a system on a platform accessible remotely, which offers, in addition to the storage of the data themselves (database) such as to be able to be consulted at any time remotely, also and

above all the possibility of interacting with the devices in the field in order to be able to configure the individual data loggers, for example by modifying, according to the needs of the period, the frequencies of the measurements.


The devices used for the measurement campaign with the widest possible spectrum of information detected are listed below: thermofluximetric Wi-Fi data loggers, microclimatic and CO2 Wi-Fi data loggers, Wi-Fi data loggers for punctual energy consumption, interfaced and manageable through the aforementioned characteristics.

This instrumentation made it possible to detect data which, when properly treated, give information on the transmittance of the vertical opaque walls and the microclimate in the school complex located in the municipality of Agnone and the transmittance of the vertical opaque walls of the headquarters of the Municipality of Agnone.

THE LOGISTICS OF THE SURVEYS

The "School Complex "

According to a detailed chrono-program, starting from the school building, we proceeded, also following the indications suggested by the ENEA technician Aversa Patrizia, with the installation of a system of plates and sensors suitable for the evaluation of thermal conductance, together with the installation of a sensor network for the assessment of indoor air quality in 4 of the classrooms chosen according to a criterion of maximum expected crowding.



In correspondence with a dedicated technical room, the installation company has installed the control unit which takes care of the telemetry of the detected data.

An accurate interfacing action as well as the experience of the technicians involved allowed us to be immediately operational, the remote monitoring immediately demonstrated the efficiency of the installed system.



Municipal Administration headquarters building of Agnone

As regards the Municipal headquarters, monitoring takes place at a room located on the second floor of the building where plates and sensors dedicated to the detection of the parameters of the thermal conductance of the opaque walls are installed.

It is important to point out that the technical choice of identifying WI-FI devices has allowed greater freedom of action in terms of installation logistics, as well as ample flexibility in the context of the monitoring technique. In fact, while the data collected by the aforementioned system, installed in the school building, have seen the interface to a local control unit that constantly communicates with the data loggers, in the case of the Municipality the data are downloaded locally using the appropriate software.



INSTRUMENTAL SURVEYS AND DATA ANALYSIS

The "School Complex"

Sampling with data transmission in real time 24h / 24 of the detected data supported by an installation action that took into account all the surrounding conditions of the building-plant system, made it possible to store a considerable amount of data whose processing led to the calculation of the transmittance of the opaque walls.

REPORT DELLA MISURA IN OPERA DELLA TRASMITTANZA TERMICA

Luogo: Città di Agnone (IS)

Data: 30/04/2022 10:56:29

Strumentazione impiegata

Termoflussmetro: MACADD 0000C1A5

Misura temperature superficiale esterna: MACADD 0000C1AB

Misura temperature superficiale interna: MACADD 0000C1AC




Misura a cura di: Città di Agnone DS

Tipologia di edificio: Edificio scolastico "G.N. D'Agnillo"

Inizio misure: 20/04/2022

Fine misure: 30/04/2022

N.Campionamenti: 1411



FINAL CONDUCTANCE: 0.190 $\frac{W}{m^2 K}$

FINAL TRANSMITTANCE: 0.184 $\frac{W}{m^2 K}$



The determined value of the thermal transmittance of opaque walls is characteristic of an environment in which there are masonry works of thermal insulation (external coat).

Municipal Administration headquarters building of Agnone

The 24h / 24 sampling of the data collected with the method of downloading the data locally, supported by an installation action that took into account all the surrounding conditions of the building-plant system, made it possible to store a considerable amount of data whose processing led to the calculation of the transmittance of the opaque walls of the building.

REPORT DELLA MISURA IN OPERA DELLA TRASMITTANZA TERMICA



Luogo: Città di Agnone (IS)

Data: 30/04/2022 11:08:39

Strumentazione Impiegata

Termoflussimetro: MACADD 0000C1A6





Misura temperature superficiale esterna: MACADD 0000C1AD

Misura temperature superficiale interna: MACADD 0000C1AA

Misura a cura di : Città di Agnone DS

Tipologia di edificio : Edificio Sede Comune di Agnone

Inizio misure : 21/04/2022 Fine misure: 30/04/2022 N.Campionamenti : 1023



FINAL CONDUCTANCE: 1.653 $\frac{W}{m^2 K}$

FINAL TRANSMITTANCE: 1.293 $\frac{W}{m^2 K}$

The determined value of the thermal transmittance of opaque walls is characteristic of an environment in which there are no masonry works for thermal insulation.

The technical / design choice of using equipment such as to offer a high installation dynamism together with the fact that they are reusable for other measurement campaigns, all combined with a 24h / 24 sampling of the data collected, has allowed us to provide a high amount of information about the behavior of opaque walls of buildings which are substantially different due to construction technique and construction period.

This measurement campaign made it possible to instrumentally identify the value of the thermal transmittance of a wall and the comparison of the two values determined by the data collected, clearly highlights how the thermal insulation of a wall can clearly determine savings in terms of energy consumption.

The contribution provided by the MoA to the Reehub + project, as part of a field monitoring of the telemetry data detected, using a 24h / 24 measurement methodology on substantially different buildings, has certainly highlighted how the instrumental approach to audit energy can unequivocally return useful and necessary information for the choice of technical interventions aimed at energy efficiency of buildings.

Seminar "The tools to support the energy requalification of buildings and the Green Public Procurement" - Training Organization

The results obtained during the measurement campaign were illustrated during the seminar of May 13, 2022 organized by the MoA. During the work of the seminar the relevant points were also touched upon:

- the good practices implemented by the REEHUB PLUS cooperation project in the field of energy requalification and energy auditing of buildings.
- The issue of Green Public Procurement (GPP), an important topic both for public bodies and for professionals and companies that work closely with the Public Administration.



- The issue of green procurement was dealt with from a regulatory and jurisprudential point of view, in a national and European context, with the presentation of good practices, advice and practical suggestions.

Last but not least, it should be noted that the partnership, which was created starting with Reehub, between the institutions, the project and the school has traced the path

towards new horizons in the field of training and preparation of the technicians of tomorrow.



Training Organization

The target group for this event were the technicians belonging to the various professional orders. The official nature and technical validity have been sanctioned by the recognition by the National Council of Engineers (CNI) of valid training credits for the completion of the free profession.

Synergy between partners

The synergistic aspect previously mentioned, has determined the birth of new issues in the field of energy efficiency, this is what was dealt with in the "Project meeting & Project ideas preparation Brindisi" held in Brindisi on 12 May 2022 by of the DITNE.

The study of the building-plant system through the interpretation of the data collected in the measurement campaign fits perfectly into the future perspective of what was dealt with in the meeting in Brindisi where on axis 2 GREENER EU - S.O. 2.3 Energy ACTIONS FOCUSED ON ENERGY EFFICIENCY, the following points have been dealt with:

- raising awareness of CO2 emissions
- energy efficiency measures aimed at specific sectors (eg culture / tourism, construction, public buildings, etc.)
- security of cross-border energy networks
- digital tools / processes for energy efficiency
- energy efficiency plans integrated into RES strategies
- adoption of EU energy rules
- Transform HUBs into One Stop Shops and further promote the adoption of European legislation (EPBD Energy Performance of Buildings Directive) on the energy efficiency of buildings

Regulatory references

Energy Efficiency Directive (EED) - EU Level

Directive 2012/27/EU of the European Parliament and of the Council of 25 October 2012 on energy efficiency amending Directives 2009/125/EC and 2010/30/EU and repealing Directives 2004/8/EC and 2006/32/EC

Council Directive 2013/12/EU of 13 May 2013 adapting Directive 2012/27/EU of the European Parliament and of the Council on energy efficiency, by reason of the accession of the Republic of Croatia

Directive (EU) 2018/844 of the European Parliament and of the Council of 30 May 2018 amending Directive 2010/31/EU on the energy performance of buildings and Directive 2012/27/EU on energy efficiency

Directive (EU) 2018/2002 of the European Parliament and of the Council of 11 December 2018 amending Directive 2012/27/EU on energy efficiency

Regulation (EU) 2018/1999 of the European Parliament and of the Council of 11 December 2018 on the Governance of the Energy Union and Climate Action, amending Regulations (EC) No 663/2009 and (EC) No 715/2009 of the European Parliament and of the Council, Directives 94/22/EC, 98/70/EC, 2009/31/EC, 2009/73/EC, 2010/31/EU, 2012/27/EU and 2013/30/EU of the European Parliament and of the Council, Council Directives 2009/119/EC and (EU) 2015/652 and repealing Regulation (EU) No 525/2013 of the European Parliament and of the Council

Decision (EU) 2019/504 of the European Parliament and of the Council of 19 March 2019 on amending Directive 2012/27/EU on energy efficiency and Regulation (EU) 2018/1999 on the Governance of the Energy Union and Climate Action, by reason of the withdrawal of the United Kingdom of Great Britain and Northern Ireland from the Union

Commission Delegated Regulation (EU) 2019/826 of 4 March 2019 amending Annexes VIII and IX to Directive 2012/27/EU of the European Parliament and of the Council on the contents of comprehensive assessments of the potential for efficient heating and cooling

Directive (EU) 2019/944 of the European Parliament and of the Council of 5 June 2019 on common rules for the internal market for electricity and amending Directive 2012/27/EU

Energy Performance Buildings Directive (EPBD) - EU Level

Directive 2010/31/EU of the European Parliament and of the Council of 19 May 2010 on the energy performance of buildings (recast)

Directive (EU) 2018/844 of the European Parliament and of the Council of 30 May 2018 amending Directive 2010/31/EU on the energy performance of buildings and Directive 2012/27/EU on energy efficiency

Regulation (EU) 2018/1999 of the European Parliament and of the Council of 11 December 2018 on the Governance of the Energy Union and Climate Action, amending Regulations (EC) No 663/2009 and (EC) No 715/2009 of the European Parliament and of the Council, Directives 94/22/EC, 98/70/EC, 2009/31/EC, 2009/73/EC, 2010/31/EU, 2012/27/EU and 2013/30/EU of the European Parliament and of the Council, Council Directives 2009/119/EC and (EU) 2015/652 and repealing Regulation (EU) No 525/2013 of the European Parliament and of the Council

Technical regulations

The EU directives are the basis for the implementation of technical regulations, which are the real tools allowing the designer to develop the new building architectures compliant to the best practise.

There are several technical standards in effect about the energy efficiency in buildings. Here, the most important ones are listed with a short description of their content.

1. EN 16247-1:2012 Energy audits - Part 1: General requirements

Summary: The European standard specifies the requirements, common methodology and deliverables for energy audits. It applies to all forms of establishments and organizations, all forms of energy and uses of energy, excluding individual private dwellings.

It covers the general requirements common to all energy audits. Specific energy audit requirements will complete the general requirements in separate parts dedicated to energy audits for buildings, industrial processes, and transportation.

2. EN 16247-2:2014 Energy audits - Part 2: Buildings:

Summary: This European Standard is applicable to specific energy audit requirements in buildings. It specifies the requirements, methodology and deliverables of an energy audit in a building or group of buildings, excluding individual private dwellings. It shall be applied in conjunction with, and is supplementary to, EN 16247-1, Energy audits — Part 1: General

requirements. It provides additional requirements to EN 16247-1 and shall be applied simultaneously.

3. EN 16247-5:2015 Energy audits - Part 5: Competence of energy auditors

Summary: This European Standard specifies the competence requirements of the energy auditor. This European Standard can be used to specify energy auditor qualification schemes at a national level; used by organizations undertaking energy audits to appoint a suitably competent energy auditor and used by organizations, in conjunction with EN 16247-1, EN 16247-2, EN 16247-3 and EN 16247-4, to ensure a good level of quality of the energy audits. This European Standard also recognizes that all the competence required can reside in the energy auditor or a team of energy auditors.

4. UNI/TS 11300-1:2014 Energy performance of buildings - Part 1: Evaluation of energy need for space heating and cooling

Summary: The technical specification provides data and methods for evaluating of energy need for space heating and cooling.

The technical specification defines the procedures for the national application of UNI EN ISO 13790:2008 according to monthly method for evaluating of energy need for space heating and cooling.

The technical specification is aimed at all the possible applications provided by the UNIEN ISO 13790:2008: evaluation of the project (design rating), energy assessment of buildings through the calculation under standard conditions (asset rating) or a specific climatic and operating conditions (tailored rating).

5. UNI/TS 11300-2:2019 Energy performance of buildings - Part 2: Evaluation of primary energy need and of system efficiencies for space heating, domestic hot water production, ventilation and lighting for non-residential buildings

Summary: The technical specification provides data and methods for evaluating: the energy need for hot water production, systems efficiencies and primary energy need for space heating and hot water production, primary energy need for ventilation, primary energy need for lighting of non-residential buildings. The technical specification applies to newly design systems, retrofitting or to existing systems - for heating only - mixed or combined heating and domestic hot water - for producing only hot water, for ventilation only systems, for combined ventilation and space heating systems, for lighting systems in non-residential buildings.

6. UNI/TS 11300-3:2010 Energy performance of buildings - Part 3: Evaluation of primary energy and system efficiencies for space cooling

Summary: This standard specifies data and procedures for the calculation of the energy performance of buildings relating to space heating and cooling and domestic hot water production. This standard is a national guideline for immediate and univocal application of technical specifications elaborated by CEN to support the Directive 2002/91/EC "Energy Performance of Buildings". This standard is divided into 3 parts: Part 1 - Determination of building energy need for space heating and cooling Part 2 - Determination of primary energy and system efficiencies for space heating and domestic hot water production. This Part 3 provides data and methods for the determination of: - seasonal average efficiency of the conditioning system- annual specific need of primary energy for space cooling.

7. UNI/TS 11300-4:2016 Energy performance of buildings - Part 4: Renewable energy and other generation systems for space heating and domestic hot water production

Summary: The technical specification calculates the energy demand for space heating and domestic hot water production if there are subsystems that provide useful thermal energy generation from renewable energy or generation methods other than the flame combustion of fossil fuels treated in UNI / TS 11300-2.

The following subsystems for production of heat and / or electricity are considered:

- Solar thermal systems;
- Combustion biomass generators;
- Heat pumps;
- Photovoltaic systems;
- Cogenerators.

They are also considered the district heating substations.

UNI/TS 11300-6:2016 Energy performance of buildings - Part 6: Evaluation of energy need for lifts, escalators and moving walkways

Summary : This technical specification provides data and methods for the determination of the electricity needs for the operation of equipment intended for lifting and transportation of persons or persons accompanied by things in a building, on the basis of the characteristics of the building and plant.

These calculation methods take into account only the electrical energy needs during periods of movement and stop of the operational phase of the life cycle.

8. EN 15232-1:2017 Energy performance of buildings - Part 1: Impact of Building Automation, Controls and Building Management

Summary : This European Standard specifies:

- a structured list of control, building automation and technical building management functions which contribute to the energy performance of buildings; functions have been categorized and structured according to building disciplines and so called Building automation and control (BAC);
- a method to define minimum requirements or any specification regarding the control, building automation and technical building management functions contributing to energy efficiency of a building to be implemented in building of different complexities;
- a factor based method to get a first estimation of the effect of these functions on typical buildings types and use profiles;
- detailed methods to assess the effect of these functions on a given building.

Agnone, 07 novembre 2022

Il Tecnico Incaricato
Ing. Diego Vincenzo SALZANO



WP T1 – Pilot action Project Main Output

Report on the measurement campaign

Annex 3- Case studies

